

# TÜRK LOYDU



## **Regulations for The Performance of The Type Tests Part 1 - Test Specification For Type Approval JAN 2016**

This latest edition incorporates all rule changes. The latest revisions are shown with a vertical line. The section title is framed if the section is revised completely. Changes after the publication of the rule are written in red colour.

Unless otherwise specified, these Rules apply to ships for which the date of contract for construction as defined in TL-PR No.29 is on or after 1<sup>st</sup> of January 2016. New rules or amendments entering into force after the date of contract for construction are to be applied if required by those rules. See Rule Change Notices on TL website for details.

"General Conditions" of the respective latest edition will be applicable (see Rules for Classification and Surveys).

If there is a difference between the rules in English and in Turkish, the rule in English is to be considered as valid. This publication is available in print and electronic pdf version. Once downloaded, this document will become UNCONTROLLED. Please check the website below for the valid version.

<http://www.turkloydu.org>

All rights are reserved by Türk Loydu, and content may not be reproduced, disseminated, published, or transferred in any form or by any means, except with the prior written permission of TL.

## **TÜRK LOYDU**

**Head Office** Postane Mah. Tersaneler Cad. No:26 Tuzla 34944 İSTANBUL / TÜRKİYE  
Tel : (90-216) 581 37 00  
Fax : (90-216) 581 38 00  
E-mail : [info@turkloydu.org](mailto:info@turkloydu.org)  
<http://www.turkloydu.org>

### **Regional Offices**

**Ankara** Eskişehir Yolu Mustafa Kemal Mah. 2159. Sokak No : 6/4 Çankaya - ANKARA / TÜRKİYE  
Tel : (90-312) 219 56 34  
Fax : (90-312) 219 68 25  
E-mail : [ankara@turkloydu.org](mailto:ankara@turkloydu.org)

**İzmir** Atatürk Cad. No :378 K.4 D.402 Kavalalılar Apt. 35220 Alsancak - İZMİR / TÜRKİYE  
Tel : (90-232) 464 29 88  
Fax : (90-232) 464 87 51  
E-mail : [izmir@turkloydu.org](mailto:izmir@turkloydu.org)

**Adana** Çınarlı Mah. Atatürk Cad. Aziz Naci İş Merkezi No:5 K.1 D.2 Seyhan - ADANA / TÜRKİYE  
Tel : (90- 322) 363 30 12  
Fax : (90- 322) 363 30 19  
E-mail : [adana@turkloydu.org](mailto:adana@turkloydu.org)

**Test Specification For Type Approval**

	<b>Page</b>
<b>A. General</b> .....	<b>1</b>
<b>B. Testing</b> .....	<b>1</b>

## AMENDMENTS

Revision	RCS No.	EIF Date*
Test Specification For Type Approval	<a href="#">04/2019</a>	01.01.2020

\* Entry into Force (EIF) Date is provided for general guidance only, EIF dates given in Rule Change Summary (RCS) are considered valid. In addition to the above stated changes, editorial corrections may have been made.

## Test Specification for Type Approval

### A. General

This Test Specification is applicable, but not confined, to electrical, electronic and programmable equipment intended for\* control, monitoring, alarm and protection systems for use in ships.

### B. Testing

These tests are to demonstrate the ability of the equipment to function as intended under the specified testing conditions.

The extent of the testing (i.e. the selection and sequence of carrying out tests and number of pieces to be tested) is to be determined upon examination and evaluation of the equipment or component subject to testing giving due regard to its intended usage.

Equipment is to be tested in its normal position if otherwise not specified in the test specification.

Relevant tests are as listed in the Table.

#### Note:

- a) These test requirements are harmonised with IEC 60092-504 "Electrical Installations in Ships - Part 504: Special features - Control and Instrumentation" and IEC 60533 "Electrical and electronic installations in ships – electromagnetic compatibility". Electrical and electronic equipment on board ships, required neither by classification rules nor by International Conventions, liable to cause electromagnetic disturbance shall be of type which fulfil the test requirements of test specification items 19 and 20.
- b) As used in this document, and in contrast to a complete performance test, a functional test is a simplified test sufficient to verify that the equipment under test (EUT) has not suffered any deterioration caused by the individual environmental tests.

### Type testing condition for equipment covered by item A.

NO.	TEST	PROCEDURE ACC. TO:*	TEST PARAMETERS	OTHER INFORMATION																					
* indicates the testing procedure which is normally to be applied. However, equivalent testing procedure may be accepted by TL provided that the requirements stated in the other columns are fulfilled. The latest edition of the normative reference applies.																									
1.	Visual inspection	-	-	- conformance to drawings, design data																					
2.	Performance test	Manufacturer performance test programme based upon specification and relevant Rule requirements. When the EUT is required to comply with an international performance standard, e.g. protection relays, verification of requirements in the standard are to be part of the performance testing required in this initial test and subsequent performance tests after environmental testing where required in this rule.	<ul style="list-style-type: none"> <li>- standard atmosphere conditions</li> <li>- temperature: 25°C ± 10°C</li> <li>- relative humidity: 60% ± 30%</li> <li>- air pressure: 96 KPa ± 10KPa</li> </ul>	<ul style="list-style-type: none"> <li>- confirmation that operation is in accordance with the requirements specified for particular system or equipment;</li> <li>- checking of self-monitoring features;</li> <li>- checking of specified protection against an access to the memory;</li> <li>- checking against effect of unerroneous use of control elements in the case of computer systems.</li> </ul>																					
3.	External power supply failure	-	<ul style="list-style-type: none"> <li>- 3 interruptions during 5 minutes;</li> <li>- switching-off time 30 s each case</li> </ul>	<ul style="list-style-type: none"> <li>- The time of 5 minutes may be exceeded if the equipment under test needs a longer time for start-up, e.g. booting sequence</li> <li>- For equipment which requires booting, one additional power supply interruption during booting to be performed</li> </ul>																					
4.	Power supply variations		AC SUPPLY	<ul style="list-style-type: none"> <li>- The time of 5 minutes may be exceeded if the equipment under test needs a longer time for start-up, e.g. booting sequence</li> <li>- For equipment which requires booting, one additional power supply interruption during booting to be performed</li> <li>Verification of: <ul style="list-style-type: none"> <li>- equipment behaviour upon loss and restoration of supply;</li> <li>- possible corruption of programme or data held in programmable electronic systems, where applicable.</li> </ul> </li> </ul>																					
	a) electric		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Combination</th> <th>Voltage variation permanent %</th> <th>Frequency variation permanent %</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>+6</td> <td>+5</td> </tr> <tr> <td>2</td> <td>+6</td> <td>-5</td> </tr> <tr> <td>3</td> <td>-10</td> <td>-5</td> </tr> <tr> <td>4</td> <td>-10</td> <td>+5</td> </tr> <tr> <td></td> <td>voltage transient 1,5 s %</td> <td>frequency transient 5 s %</td> </tr> <tr> <td>5</td> <td>+20</td> <td>+10</td> </tr> <tr> <td>6</td> <td>-20</td> <td>-10</td> </tr> </tbody> </table>		Combination	Voltage variation permanent %	Frequency variation permanent %	1	+6	+5	2	+6	-5	3	-10	-5	4	-10	+5		voltage transient 1,5 s %	frequency transient 5 s %	5	+20	+10
Combination	Voltage variation permanent %	Frequency variation permanent %																							
1	+6	+5																							
2	+6	-5																							
3	-10	-5																							
4	-10	+5																							
	voltage transient 1,5 s %	frequency transient 5 s %																							
5	+20	+10																							
6	-20	-10																							
	b) pneumatic and hydraulic		DC SUPPLY																						
			<table border="1" style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td>Voltage tolerance continuous</td> <td style="text-align: center;">±10%</td> </tr> <tr> <td>Voltage cyclic variation</td> <td style="text-align: center;">5%</td> </tr> <tr> <td>Voltage ripple</td> <td style="text-align: center;">10%</td> </tr> </tbody> </table>	Voltage tolerance continuous	±10%	Voltage cyclic variation	5%	Voltage ripple	10%																
Voltage tolerance continuous	±10%																								
Voltage cyclic variation	5%																								
Voltage ripple	10%																								

NO.	TEST	PROCEDURE ACC. TO:*	TEST PARAMETERS	OTHER INFORMATION
			Electric battery supply: - +30% to -25% for equipment connected to charging battery or as determined by the charging/discharging characteristics, including ripple voltage from the charging device; - +20% to -25% for equipment not connected to the battery during charging.  Pressure: $\pm 20\%$ Duration: 15 minutes	
5.	Dry heat (see note 1)	IEC 60068-2-2 Test Bb for non-heat dissipating equipment	Temperature: $55^{\circ} \pm 2^{\circ}\text{C}$ Duration: 16 hours or Temperature: $70^{\circ}\text{C} \pm 2^{\circ}\text{C}$ Duration: 16 hours	<ul style="list-style-type: none"> <li>- equipment operating during conditioning and testing;</li> <li>- functional test (b) during the last hour at the test temperature.</li> <li>- for equipment specified for increased temperature the dry heat test is to be conducted</li> <li>- at the agreed test temperature and duration.</li> </ul>
		IEC 60068-2-2 Test Be for heat dissipating equipment	Temperature: $55^{\circ} \pm 2^{\circ}\text{C}$ Duration: 16 hours or Temperature: $70^{\circ}\text{C} \pm 2^{\circ}\text{C}$ Duration: 16 hours	<ul style="list-style-type: none"> <li>- equipment operating during conditioning and testing with cooling system on if provided;</li> <li>- functional test (b) during the last hour at the test temperature.</li> <li>- for equipment specified for increased temperature the dry heat test is to be conducted at the agreed test temperature and duration</li> </ul>
6.	Damp heat	IEC 60068-2-30 test D <sub>b</sub>	Temperature: $55^{\circ}\text{C}$ Humidity: 95% Duration: 2 cycles 2 x (12 + 12 hours)	<ul style="list-style-type: none"> <li>- measurement of insulation resistance before test;</li> <li>- the test shall start with <math>25^{\circ}\text{C} \pm 3^{\circ}\text{C}</math> and at least 95% humidity;</li> <li>- equipment operating during the complete first cycle and switched off during second cycle except for functional test;</li> <li>- functional test during the first 2 hours of the first cycle at the test temperature and during the last 2 hours of the second cycle at the test</li> </ul>

NO.	TEST	PROCEDURE ACC. TO:*	TEST PARAMETERS	OTHER INFORMATION
				<ul style="list-style-type: none"> <li>- temperature; Duration of the second cycle can be extended due to more convenient handling of the functional test.</li> <li>- recovery at standard atmosphere conditions;</li> <li>- insulation resistance measurements and performance test.</li> </ul>
7.	Vibration	IEC 60068-2-6 Test F <sub>c</sub>	<p>2<sup>+3</sup> Hz to 13.2 Hz – amplitude ±1mm -0</p> <p>13.2 Hz to 100 Hz – acceleration ± 0.7 g. For severe vibration conditions such as, e.g. on diesel engines, air compressors, etc.: 2.0 Hz to 25 Hz – amplitude ±1.6 mm 25.0 Hz to 100 Hz – acceleration ± 4.0 g.</p> <p>Note: More severe conditions may exist for example on exhaust manifolds or fuel oil injection systems of diesel engines. For equipment specified for increased vibration levels the vibration test is to be conducted at the agreed vibration level, frequency range and duration. Values may be required to be in these cases 40 Hz to 2000 Hz - acceleration ± 10.0g at 600°C, duration 90 min.*</p>	<ul style="list-style-type: none"> <li>- duration in case of no resonance condition 90 minutes at 30 Hz;</li> <li>- duration at each resonance frequency at which Q<sub>r</sub>: 2 is recorded - 90 minutes;</li> <li>- during the vibration test, functional tests are to be carried out;</li> <li>- tests to be carried out in three mutually perpendicular planes;</li> <li>- it is recommended as guidance that Q does not exceed 5.</li> <li>- where sweep test is to be carried out instead of the discrete frequency test and a number of resonant frequencies is detected close to each other, duration of the test is to be 120 min. Sweep over a restricted frequency range between 0.8 and 1.2 times the critical frequencies can be used where appropriate.</li> </ul> <p>Note: Critical frequency is a frequency at which the equipment being tested may exhibit:</p> <ul style="list-style-type: none"> <li>- malfunction and/or performance deterioration</li> <li>- mechanical resonances and/or other response effects occur, e.g. chatter</li> </ul>
8.	Inclination	IEC 60092-504	Static 22.5°	<ul style="list-style-type: none"> <li>a) inclined to the vertical at an angle of at least 22.5°</li> <li>b) inclined to at least 22.5° on the other side of the vertical and in the same plane as in (a),</li> <li>c) inclined to the vertical at an angle of at least 22.5° in plane at right angles to that used in (a),</li> <li>d) inclined to at least 22.5° on the other side of the vertical and in the same plane as in (c).</li> </ul> <p>Note: The period of testing in each position should be sufficient to fully evaluate the</p>



NO.	TEST	PROCEDURE ACC. TO:*	TEST PARAMETERS	OTHER INFORMATION														
			Dynamic 22.5°	<p>behaviour of the equipment.</p> <p>Using the directions defined in a) to d) above, the equipment is to be rolled to an angle of 22.5° each side of the vertical with a period of 10 seconds. The test in each direction is to be carried out for not less than 15 minutes. On ships for the carriage of liquified gases and chemicals, the emergency power supply is to remain operational with the ship flooded up to a maximum final athwart ship inclination of 30°.</p> <p>Note: These inclination tests are normally not required for equipment with no moving parts</p>														
9.	Insulation resistance	<table border="1"> <thead> <tr> <th rowspan="2">Rated supply voltage Un (V)</th> <th rowspan="2">Test voltage (D.C. voltage) (V)</th> <th colspan="2">Min. insulation resistance</th> </tr> <tr> <th>before test M ohms</th> <th>after test M ohms</th> </tr> </thead> <tbody> <tr> <td>Un ≤ 65</td> <td>2 x Un min. 24V</td> <td>10</td> <td>1,0</td> </tr> <tr> <td>Un &gt; 65</td> <td>500</td> <td>100</td> <td>10</td> </tr> </tbody> </table>	Rated supply voltage Un (V)	Test voltage (D.C. voltage) (V)	Min. insulation resistance		before test M ohms	after test M ohms	Un ≤ 65	2 x Un min. 24V	10	1,0	Un > 65	500	100	10		<ul style="list-style-type: none"> <li>- For high voltage equipment, reference is made to TL- R E11.</li> <li>- insulation resistance test is to be carried out before and after: damp heat test, cold test, salt mist test and high voltage test;</li> <li>- between all phases and earth; and where appropriate, between the phases.</li> </ul> <p>Note: Certain components e.g. for EMC protection may be required to be disconnected for this test.</p>
Rated supply voltage Un (V)	Test voltage (D.C. voltage) (V)	Min. insulation resistance																
		before test M ohms	after test M ohms															
Un ≤ 65	2 x Un min. 24V	10	1,0															
Un > 65	500	100	10															
10.	High voltage	<table border="1"> <thead> <tr> <th>Rated voltage Un (V)</th> <th>Test voltage (A.C. voltage 50 or 60Hz) (V)</th> </tr> </thead> <tbody> <tr> <td>Up to 65</td> <td>2 x Un + 500</td> </tr> <tr> <td>66 to 250</td> <td>1500</td> </tr> <tr> <td>251 to 500</td> <td>2000</td> </tr> <tr> <td>501 to 690</td> <td>2500</td> </tr> </tbody> </table>	Rated voltage Un (V)	Test voltage (A.C. voltage 50 or 60Hz) (V)	Up to 65	2 x Un + 500	66 to 250	1500	251 to 500	2000	501 to 690	2500		<ul style="list-style-type: none"> <li>- For high voltage equipment, reference is made to TL- R E11.</li> <li>- separate circuits are to be tested against each other and all circuits connected with each other tested against earth;</li> <li>- printed circuits with electronic components may be removed during the test;</li> <li>- period of application of the test voltage: 1 minute</li> </ul>				
Rated voltage Un (V)	Test voltage (A.C. voltage 50 or 60Hz) (V)																	
Up to 65	2 x Un + 500																	
66 to 250	1500																	
251 to 500	2000																	
501 to 690	2500																	
11.	Cold	IEC 60068-2-1	<p>Temperature: +5°C ± 3°C Duration: 2 hours or Temperature: -25°C ± 3°C Duration: 2 hours (see note 2)</p>	<ul style="list-style-type: none"> <li>- initial measurement of insulation resistance;</li> <li>- equipment not operating during conditioning and testing except for functional test;</li> <li>- functional test during the last hour at the test temperature;</li> <li>- insulation resistance measurement and the functional test after recovery</li> </ul>														
12.	Salt mist	IEC 60068-2-52 Test Kb	Four spraying periods with a storage of 7 days after each.	<ul style="list-style-type: none"> <li>- initial measurement of insulation resistance and initial functional test;</li> <li>- equipment not operating during conditioning;</li> <li>- functional test on the 7th day of each</li> </ul>														

NO.	TEST	PROCEDURE ACC. TO:*	TEST PARAMETERS	OTHER INFORMATION
				<p>storage period;</p> <ul style="list-style-type: none"> <li>- insulation resistance measurement and performance test 4 to 6h after recovery. (see Note 3)</li> <li>- on completion of exposure, the equipment shall be examined to verify that deterioration or corrosion (if any) is superficial in nature.</li> </ul>
13.	Electrostatic discharge	IEC 61000-4-2	<p>Contact discharge: 6kV  Air discharge: 2kV, 4kV, 8kV  Interval between single discharges: 1 sec. No. of pulses: 10 per polarity  According to test level 3.</p>	<ul style="list-style-type: none"> <li>- to simulate electrostatic discharge as may occur when persons touch the appliance;</li> <li>- the test is to be confined to the points and surfaces that can normally be reached by the operator;</li> </ul> <p>Performance Criterion B (See Note 4).</p>
14.	Electromagnetic field	IEC 61000-4-3	<p>Frequency range: 80 MHz to 6 GHz  Modulation**: 80% AM at 1000Hz  Field strength: 10V/m  Frequency sweep rate: <math>\leq 1.5 \times 10^{-3}</math> decades/s (or 1%/3 sec)  According to test level 3.</p>	<ul style="list-style-type: none"> <li>- to simulate electromagnetic fields radiated by different transmitters;</li> <li>- the test is to be confined to the appliances exposed to direct radiation by transmitters at their place of installation.</li> <li>- Performance criterion A (See Note 5)</li> </ul> <p>**If for tests of equipment an input signal with a modulation frequency of 1000 Hz is necessary a modulation frequency of 400 Hz may be chosen.</p> <p>- If an equipment is intended to receive radio signals for the purpose of radio communication (e.g. wifi router, remote radio controller), then the immunity limits at its communication frequency do not apply, subject to the provisions in TL- R E22.5.2.</p>
15.	Conducted low Frequency		<p>AC:  Frequency range: rated frequency to 200th harmonic;  Test voltage (rms): 10% of supply to 15th harmonic reducing to 1% at 100th harmonic and maintain this level to the 200th harmonic, min 3 V r.m.s, max 2 W.</p> <p>DC:  Frequency range: 50 Hz - 10 kHz;</p>	<ul style="list-style-type: none"> <li>- to stimulate distortions in the power supply system generated for instance, by electronic consumers and coupled in as harmonics;</li> <li>- performance criterion A (see Note 5).</li> <li>- See figure - "Test set-up"</li> <li>- for keeping max. 2W, the voltage of the test signal may be lower.</li> </ul>
16.	Conducted Radio Frequency	IEC 61000-4-6	<p>AC, DC, I/O ports and signal/control lines:  Frequency range: 150 kHz - 80 MHz Amplitude: 3 V rms (See Note 6) Modulation ***: 80% AM</p>	<ul style="list-style-type: none"> <li>- Equipment design and the choice of materials is to stimulate electromagnetic fields coupled as high frequency into the test</li> </ul>


NO.	TEST	PROCEDURE ACC. TO:*	TEST PARAMETERS	OTHER INFORMATION
			at 1000 Hz Frequency sweep range: $\leq 1.5 \times 10^{-3}$ decades/s (or 1%/3sec.) According to test level 2.	specimen via the connecting lines. - performance criterion A (see Note 5). *** If for tests of equipment an input signal with a modulation frequency of 1000 Hz is necessary a modulation frequency of 400 Hz may be chosen.
17.	Electrical Fast Transients / Burst	IEC 61000-4-4	Single pulse rise time: 5 ns (between 10% and 90% value) Single pulse width: 50 ns (50% value) Amplitude (peak): 2kV line on power supply port/earth; 1kV on I/O data control and communication ports (coupling clamp) Pulse period: 300 ms; Burst duration: 15 ms; Duration/polarity: 5 min According to test level 3.	- arcs generated when actuating electrical contacts; - interface effect occurring on the power supply, as well as at the external wiring of the test specimen; - performance criterion B (see Note 4).
18.	Surge	IEC 61000-4-5	Test applicable to AC and DC power ports Open-circuit voltage: Pulse rise time: 1.2 $\mu$ s (front time) Pulse width: 50 $\mu$ s (time to half value) Amplitude (peak): 1kV line/earth; 0.5kV line/line Short-circuit current: Pulse rise time: 8 $\mu$ s (front time) Pulse width: 20 $\mu$ s (time to half value) Repetition rate: $\geq 1$ pulse/min No of pulses: 5 per polarity Application: continuous According to test level 2.	- interference generated for instance, by switching "ON" or "OFF" high power inductive consumers; - test procedure in accordance with figure 10 of the standard for equipment where power and signal lines are identical; performance criterion B (see Note 4).

NO.	TEST	PROCEDURE ACC. TO:*	TEST PARAMETERS	OTHER INFORMATION																												
19.	Radiated Emission	CISPR 16-2-3 IEC 60945 for 156-165 MHz	<p>Limits below 1000 MHz</p> <p>For equipment installed in the bridge and deck zone.</p> <table border="1" data-bbox="1043 347 1480 544"> <thead> <tr> <th>Frequency range:</th> <th>Quasi peak limits:</th> </tr> </thead> <tbody> <tr> <td>0.15 - 0.3 MHz</td> <td>80 - 52 dB<math>\mu</math>V/m</td> </tr> <tr> <td>0.3 - 30 MHz</td> <td>52 - 34 dB<math>\mu</math>V/m</td> </tr> <tr> <td>30 - 1000 MHz</td> <td>54 dB<math>\mu</math>V/m</td> </tr> <tr> <td>except for:</td> <td></td> </tr> <tr> <td>156 - 165 MHz</td> <td>24 dB<math>\mu</math>V/m</td> </tr> </tbody> </table> <p>For equipment installed in the general power distribution zone.</p> <table border="1" data-bbox="1043 691 1480 911"> <thead> <tr> <th>Frequency range:</th> <th>Quasi peak limits:</th> </tr> </thead> <tbody> <tr> <td>0.15 - 30 MHz</td> <td>80 - 50 dB<math>\mu</math>V/m</td> </tr> <tr> <td>30 - 100 MHz</td> <td>60 - 54 dB<math>\mu</math>V/m</td> </tr> <tr> <td>100 - 1000 MHz</td> <td>54 dB<math>\mu</math>V/m</td> </tr> <tr> <td>except for:</td> <td></td> </tr> <tr> <td>156 - 165 MHz</td> <td>24 dB<math>\mu</math>V/m</td> </tr> </tbody> </table> <p>Limits above 1000 MHz</p> <table border="1" data-bbox="1010 970 1447 1118"> <thead> <tr> <th>Frequency range:</th> <th>Average limit:</th> </tr> </thead> <tbody> <tr> <td>1000-6000 MHz</td> <td>54 dB<math>\mu</math>V/m</td> </tr> </tbody> </table>	Frequency range:	Quasi peak limits:	0.15 - 0.3 MHz	80 - 52 dB $\mu$ V/m	0.3 - 30 MHz	52 - 34 dB $\mu$ V/m	30 - 1000 MHz	54 dB $\mu$ V/m	except for:		156 - 165 MHz	24 dB $\mu$ V/m	Frequency range:	Quasi peak limits:	0.15 - 30 MHz	80 - 50 dB $\mu$ V/m	30 - 100 MHz	60 - 54 dB $\mu$ V/m	100 - 1000 MHz	54 dB $\mu$ V/m	except for:		156 - 165 MHz	24 dB $\mu$ V/m	Frequency range:	Average limit:	1000-6000 MHz	54 dB $\mu$ V/m	<ul style="list-style-type: none"> <li>- procedure in accordance with the standard but distance 3 m between equipment and antenna</li> <li>- for the frequency band 156 MHz to 165 MHz the measurement shall be repeated with a receiver bandwidth of 9 kHz (as per IEC 60945).</li> <li>- alternatively the radiation limit at a distance of 3 m from the enclosure port over the frequency 156 MHz to 165 MHz shall be 30 dB micro-V/m peak (as per IEC 60945).</li> <li>- procedure in accordance with the standard (distance 3 m between equipment and antenna)</li> <li>- Equipment intended to transmit radio signals for the purpose of radio communication (e.g. wifi router, remote radio controller) may be exempted from limit, within its communication frequency range, subject to the provisions in TL- R E22.5.2</li> </ul>
Frequency range:	Quasi peak limits:																															
0.15 - 0.3 MHz	80 - 52 dB $\mu$ V/m																															
0.3 - 30 MHz	52 - 34 dB $\mu$ V/m																															
30 - 1000 MHz	54 dB $\mu$ V/m																															
except for:																																
156 - 165 MHz	24 dB $\mu$ V/m																															
Frequency range:	Quasi peak limits:																															
0.15 - 30 MHz	80 - 50 dB $\mu$ V/m																															
30 - 100 MHz	60 - 54 dB $\mu$ V/m																															
100 - 1000 MHz	54 dB $\mu$ V/m																															
except for:																																
156 - 165 MHz	24 dB $\mu$ V/m																															
Frequency range:	Average limit:																															
1000-6000 MHz	54 dB $\mu$ V/m																															
20.	Conducted Emission	CISPR 16-2-1	<p>Test applicable to AC and DC power ports</p> <p>For equipment installed in the bridge and deck zone.</p> <table border="1" data-bbox="1043 1281 1480 1393"> <thead> <tr> <th>Frequency range:</th> <th>Limits:</th> </tr> </thead> <tbody> <tr> <td>10 - 150 kHz</td> <td>96 - 50 dB<math>\mu</math>V</td> </tr> <tr> <td>150 - 350 kHz</td> <td>60 - 50 dB<math>\mu</math>V</td> </tr> <tr> <td>350 kHz - 30 MHz</td> <td>50 dB<math>\mu</math>V</td> </tr> </tbody> </table> <p>For equipment installed in the general power</p>	Frequency range:	Limits:	10 - 150 kHz	96 - 50 dB $\mu$ V	150 - 350 kHz	60 - 50 dB $\mu$ V	350 kHz - 30 MHz	50 dB $\mu$ V																					
Frequency range:	Limits:																															
10 - 150 kHz	96 - 50 dB $\mu$ V																															
150 - 350 kHz	60 - 50 dB $\mu$ V																															
350 kHz - 30 MHz	50 dB $\mu$ V																															

NO.	TEST	PROCEDURE ACC. TO:*	TEST PARAMETERS	OTHER INFORMATION								
			distribution zone. <table border="1" data-bbox="1010 244 1451 357"> <thead> <tr> <th data-bbox="1010 244 1234 272">Frequency range:</th> <th data-bbox="1234 244 1451 272">Limits:</th> </tr> </thead> <tbody> <tr> <td data-bbox="1010 272 1234 301">10 - 150 kHz</td> <td data-bbox="1234 272 1451 301">120 - 69 dB<math>\mu</math>V</td> </tr> <tr> <td data-bbox="1010 301 1234 330">150 - 500 kHz</td> <td data-bbox="1234 301 1451 330">79 dB<math>\mu</math>V</td> </tr> <tr> <td data-bbox="1010 330 1234 357">0.5 - 30 MHz</td> <td data-bbox="1234 330 1451 357">73 dB<math>\mu</math>V</td> </tr> </tbody> </table>	Frequency range:	Limits:	10 - 150 kHz	120 - 69 dB $\mu$ V	150 - 500 kHz	79 dB $\mu$ V	0.5 - 30 MHz	73 dB $\mu$ V	
Frequency range:	Limits:											
10 - 150 kHz	120 - 69 dB $\mu$ V											
150 - 500 kHz	79 dB $\mu$ V											
0.5 - 30 MHz	73 dB $\mu$ V											
21.	Flame retardant	IEC 60092-101 or  IEC 60695-11-5	Flame application: 5 times 15 s each. Interval between each application: 15s or 1 time 30s. Test criteria based upon application. The test is performed with the EUT or housing of the EUT applying needle-flame test method.	<ul style="list-style-type: none"> <li>- the burnt out or damaged part of the specimen by not more than 60 mm long.</li> <li>- no flame, no incandescence or</li> <li>- in the event of a flame or incandescence being present, it shall extinguish itself within 30 s of the removal of the needle flame without full combustion of the test specimen.</li> <li>- any dripping material shall extinguish itself in such a way as not to ignite a wrapping tissue. The drip height is 200 mm <math>\pm</math> 5 mm.</li> </ul>								

**Notes:**

1. Dry heat at 70°C is to be carried out to automation, control and instrumentation equipment subject to high degree of heat, for example mounted in consoles, housing, etc. together with other heat dissipating power equipment.
2. For equipment installed in non-weather protected locations or cold locations test is to be carried out at -25°C.
3. Salt mist test is to be carried out for equipment installed in weather exposed areas.
4. Performance Criterion B: (For transient phenomena): The EUT shall continue to operate as intended after the tests. No degradation of performance or loss of function is allowed as defined in the technical specification published by the manufacturer. During the test, degradation or loss of function or performance which is self recoverable is however allowed but no change of actual operating state or stored data is allowed.
5. Performance Criterion A: (For continuous phenomena): The Equipment Under Test shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed as defined in relevant equipment standard and the technical specification published by the manufacturer.
6. For equipment installed on the bridge and deck zone, the test levels shall be increased to 10V rms for spot frequencies in accordance with IEC 60945 at 2, 3, 4, 6.2, 8.2, 12.6, 16.5, 18.8, 22, 25 MHz.



**Figure - Test Set-up – Conducted Low Frequency Test**